


## Aquaporin Inside™ HFFO 2 - Standard Test Setup

### MODULE SPECIFICATIONS

Aquaporin Inside™ coating:	On lumen side of fiber
Active area (lumen side/shell side):	2.3 m <sup>2</sup>
Inner diameter of fibers:	195 μm
Module dimensions:	300 mm long, 70 mm in diameter



Schematic description of the applied single-pass testing method used in testing of 2.3 m<sup>2</sup> modules; FV - flow meter, P - manometer, C - conductivity meter, TMP - transmembrane pressure.

Feed out-flow from the module was calculated and subtracted from the feed in-flow the module in order to calculate flux through the membrane according to eq. 1.

$$J_w = \frac{\dot{Q}_{Feed} - \dot{Q}_{Concentrate}}{A} \quad (1)$$

where:

$J_w$	is water flux (L/m <sup>2</sup> h)
$\dot{Q}_{Feed}$	is flow rate of feed (L/h)
$\dot{Q}_{Concentrate}$	is flow rate of concentrate (L/h)
$A$	is membrane area (m <sup>2</sup> )

Conductivity of the concentrated feed solution was measured in order to calculate reverse salt flux according to the eq. 2.

$$J_s = \frac{\dot{Q}_{Concentrate}}{A} \kappa \cdot B \quad (2)$$

where:

$J_s$	is reverse salt flux (L/m <sup>2</sup> h)
$\dot{Q}_{Concentrate}$	is flow rate of concentrate (L/h)
$A$	is membrane area (m <sup>2</sup> )
$\kappa$	is conductivity (μS/cm)
$B$	is proportionality coefficient (0,5362 μS/cm per 1 mg/L of NaCl)